SIEMENS

Product data sheet

3RP1555-1AP30



TIME RELAY, CLOCK-PULSE RELAY 15 TIME SETTING RANGES AC 24 V DC 200... 240 V, WITH LED

General technical details:		
product brand name		SIRIUS
product designation		timing relay
Protection class IP / on the front		IP40
Protection class IP / of the terminal		IP20
mounting position		any
Supply voltage frequency		
• 1 / for auxiliary and control current circuit		
initial rated value	Hz	50
final rated value	Hz	60
Product function		
star-delta circuit		No
 with auxiliary voltage / pulse-shaping 		No
• at the relay outputs / changeover delayed/without delay		No
Product component / semi-conductor output		No
Product extension / optional / remote control		No
Product extension / strictly required / remote control		No
Installation altitude / at a height over sea level / maximum	m	2,000
Ambient temperature		
during storage	°C	-40 +85

during operating	°C	-25 +60		
during transport	°C	-40 +85		
Relative humidity				
during operating phase	% 15 70			
Conductor-bound parasitic coupling BURST / according to IEC 61000-4-4	-	2 kV network connection / 1 kV control connection		
Conductor-bound parasitic coupling conductor-earth SURGE / according to IEC 61000-4-5		2 KV		
Conductor-bound parasitic coupling conductor-conductor SURGE / according to IEC 61000-4-5		1 kV		
Electrostatic discharge / according to IEC 61000-4-2		4 kV contact discharge / 8 kV air discharge		
Field-bound parasitic coupling / according to IEC 61000-4-3		10 V/m		
Resistance against vibration		10 55 Hz / 0.35 mm		
Impulse voltage resistance / rated value	V	4,000		
Insulation voltage / rated value	V	300		
Active power loss / total / typical	W	2		
Item designation / according to DIN 40719 extendable after IEC 204-2 / according to IEC 750		К		
Item designation / according to DIN EN 61346-2		К		
Category / according to EN 954-1		none		
Protection against electrical shock		finger-safe		

Switching Function:

ownoning ranouon.	
Switching function	
• slow-operating	No
making pulse contact	No
 firmly clocked beginning with pulse 	No
 firmly clocked beginning with pause 	No
relapse delayed	No
 variably clocked start with impulse 	No
 impuls variably clocked start with pause 	Yes
with auxiliary voltage	
 in an additive way slow-operating 	No
temporary line fault	No
relapse delayed	No
 without auxiliary voltage / relapse delayed 	No
 slow-operating/instantaneous contact 	No
with auxiliary voltage	
 relapse delayed/instantaneous contact 	No
 slow-operating/relapse delayed/instantaneous contact 	No
 firmly clocked beginning with pause/instantaneous contact 	No

making pulse contact/instantaneous contact		No
with auxiliary voltage		
 temporary line fault/instantaneous contact 		No
 pulse modelling/instantaneous contact 		No
 slow-operating/instantaneous contact 		No
General details:		
Type of voltage / of the controlled supply voltage		AC/DC
Control supply voltage frequency		
•1	Hz	50 60
Control supply voltage		
•1		
• at 50 Hz / for AC / rated value	V	24
• at 60 Hz / for AC / rated value	V	24
• for DC / rated value	V	24
•2		
• at 50 Hz		
• for AC	V	200 240
• at 60 Hz		
• for AC	V	200 240
Operating range factor control supply voltage rated value		
• at 50 Hz		
• for AC		0.85 1.1
• at 60 Hz		
• for AC		0.85 1.1
• for DC		0.85 1.1
Auxiliary circuit:		

Operating current / of auxiliary contacts		
 as normally closed contact / for AC-15 		
• at 24 V	А	3
• at 250 V	А	3
 as normally open contact / for AC-15 		
• at 24 V	А	3
• at 250 V	А	3
• at AC-15		
• maximum	А	3
• at DC-13		
• at 24 V	А	1
• at 125 V	А	0.2
• at 250 V	А	0.1

Number of NC contacts / delayed switching	0
Number of NC contacts / non-delayed	0
Number of NO contacts / delayed switching	0
Number of NO contacts / non-delayed	0
Number of change-over switches / delayed switching	1
Number of change-over switches / non-delayed	0

Short-circuit:


Design of the fuse link / for short-circuit protection of the auxiliary switch / required	fuse gL/gG: 4 A
Type of mounting	screw and snap-on mounting onto 35 mm standard mounting rail

Installation/mounting/dimensions:					
Width	mm	22.5			
Height	mm	83			
Depth	mm	91			
Distance, to be maintained, to the ranks assembly					
• upwards	mm	0			
forwards	mm	0			
• sidewards	mm	0			
backwards	mm	0			
downwards	mm	0			
Distance, to be maintained, to earthed part					
backwards	mm	0			
• sidewards	mm	0			
• upwards	mm	0			
forwards	mm	0			
downwards	mm	0			
Distance, to be maintained, conductive elements					
downwards	mm	0			
backwards	mm	0			
• sidewards	mm	0			
• forwards	mm	0			
• upwards	mm	0			

Connections:				
Design of the snap-on socket base	none			
Design of the electrical connection				
• jumper socket	No			
 for auxiliary and control current circuit 	screw-type terminals			

Type of the connecta contacts / solid	ble conductor cros	s-section / for auxiliary	_	0.5 4 r	mm², 2x (0.5 2.5 n	nm²)
Conductor cross-sec contact / solid	tion that can be cor	nnected / for auxiliary	_			
• minimum			mm²	0.5		
• maximum			mm²	4		
Type of the connecta contacts / finely strar		s-section / for auxiliary or end processing	_	0.5 2.5 mm², 2x (0.5 1.5 mm²)		
Conductor cross-sec contact / finely strand		nnected / for auxiliary r end processing	_			
• minimum			mm²	0.5		
• maximum			mm²	2.5		
Type of the connecta conductors / for auxi		s-section / for AWG		2x (20	14)	
AWG number / as coo for auxiliary contact	ded connectable co	nductor cross-section /				
• minimum				20		
• maximum				14		
Certificates/approv	/als:					
Verification of suitabi	ility			CE / UL	/ CSA	
General Product Ap	proval				Declaration of Conformity	Test Certificates
	CSA CSA	GOST			EG-Konf.	<u>Special Test</u> <u>Certificate</u>
Shipping Approval						
BUREAU VERITAS	ĴÅ DNV DNV	GL	Lloyd's Register Lrs		PRS	RINA
Shipping Approval	other					
RMRS	Confirmation	<u>other</u>	Environmenta Confirmations			
Further information	n:					
Information- and Dow http://www.siemens.co						
Industry Mall (Online http://www.siemens.co		/mall				
CAx-Online-Generato						

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) http://support.automation.siemens.com/WW/view/en/3RP1555-1AP30/all



last change:

Feb 4, 2013